



ADDENDUM #1
TO REQUEST FOR PROPOSALS FOR
WELL 13A TREATMENT FACILITY
PW NO. 22-02

This addendum contains following clarification information:

1. The Bid Opening Date has been changed to Wednesday, June 15, 2022 at 10 am.
2. All materials and equipment that are contact with the potable water must be NSF 60/61 certified per Section 01 33 00 1.8.E.

3. **SECTION 11244 Miscellaneous Chemical Feed Equipment**

Part 2.1.B and 2.1.D – **Only ferric chloride will be used. No other chemicals**

Part 2.1.F - **Materials shall be compatible with ferric chloride, FKM is acceptable.**

Part 2.1.G **Replace chlorine with ferric chloride.**

Part 2.1.H - **the plan is to mount the pump directly over the tank or on the top of the tank and utilize a foot valve/screen in-side the tank. A y-strainer is not required.**

Part 2.1.M - **Decanter shall have NSF 61 certification.**

CITY OF LAKEWOOD
PUBLIC WORKS CONTRACT 22-02
WELL 13A TREATMENT FACILITY
ADDENDUM NO.1

NOTICE TO BIDDER

Bidder shall acknowledge receipt of this addendum by detaching, signing, and attaching to his bid document, one (1) copy of this sheet. I,

Contractor

Address, City, State, Zip

hereby acknowledge receipt of Addendum No.1 to specifications, bid documents and drawings, for the Well 13A Treatment Facility, Public Works No. 22-02 and have considered these revisions in the preparation of my proposal. This addendum shall become a part of any contract made pursuant hereto.

Date: _____

Contractor's Signature: _____

Contractor's Name: _____