



ADDENDUM #3
TO REQUEST FOR PROPOSALS FOR
WELL 13A TREATMENT FACILITY
PW NO. 22-02

This addendum contains following clarification information:

1. Disinfection of facilities shall include the water storage tank, Tank 5, and shall be in accordance with AWWA C652-11.
2. Disinfection of pipeline shall include the existing 24" line, which is approximately 1600 LF.
3. The chemical conduits trench details on C-5 and C-6 reference a Pavement Section detail 1 which doesn't exist. Please clarify if the pavement repair Detail 4/C-5 applies to all trenching in the street and within paved areas of the plant. For bid purposes, please provide an assumed thickness of aggregate base.

Response: Pavement repair Detail 4/C-5 applies to all trenching in the street and within paved areas of the plant. Assume 6" thickness of the aggregate base.

CITY OF LAKEWOOD
PUBLIC WORKS CONTRACT 22-02
WELL 13A TREATMENT FACILITY
ADDENDUM NO.3

NOTICE TO BIDDER

Bidder shall acknowledge receipt of this addendum by detaching, signing, and attaching to his bid document, one (1) copy of this sheet. I,

Contractor

Address, City, State, Zip

hereby acknowledge receipt of Addendum No.3 to specifications, bid documents and drawings, for the Well 13A Treatment Facility, Public Works No. 22-02 and have considered these revisions in the preparation of my proposal. This addendum shall become a part of any contract made pursuant hereto.

Date: _____

Contractor's Signature: _____

Contractor's Name: _____