

CITY OF LAKEWOOD
Building & Safety Division
5050 Clark Avenue
Lakewood, CA 90712
(562) 866-9771, Ext. 2350

SMOKE AND CARBON MONOXIDE DETECTORS NOTICE

California State Law requires, where a permit is obtained for alterations, repairs or additions with a valuation exceeding one thousand dollars (\$1,000), existing dwellings **SHALL** be provided with a carbon monoxide alarm at any hallway or room leading to a bedroom (each floor level). Also smoke detectors **SHALL** be installed in each bedroom and the adjacent hallway or room leading to a bedroom.

FINAL INSPECTION REQUIRED

SMOKE DETECTORS & CARBON MONOXIDE DETECTORS ARE REQUIRED TO BE INSTALLED & SHALL BE INSPECTED BY THE BUILDING DEPT. BEFORE FINAL INSPECTION SIGN OFF.


NOTE: COMMENCING JULY 1, 2014, ALL SMOKE ALARMS INCLUDING COMBINATION SMOKE ALARMS, THAT ARE SOLELY BATTERY POWERED SHALL CONTAIN A NONREPLACEABLE, NONREMOVABLE BATTERY THAT IS CAPABLE OF POWERING THE SMOKE ALARM FOR AT LEAST 10 YEARS.

All detectors and alarms shall be UL listed and approved by the California State Fire Marshall Office and installed per manufacturer's installation instructions.

NOTE: Range hood vent (T-Top Roof Jack) require wire mesh type jack

- Place a smoke alarm in each bedroom and any hallway or room that leads to a bedroom. Place a smoke alarm on each level.

- Place carbon monoxide alarms adjacent to the bedrooms and on each level.
- Battery operated are allowed if they are 10 year batteries with State Fire Marshall approval.
- Do NOT install within 3 ft. of the following: door to a bathroom containing a tub or shower, forced air supply ducts, ceiling or whole house fan, or other high air flow areas.



- Coloque una alarma de humo en cada dormitorio y cualquier pasillo o habitación que conduce a un dormitorio. Coloque una alarma de humo en cada nivel.
- Coloque alarmas de monóxido de carbono adyacentes a los dormitorios y en cada nivel.
- Los detectores con pilas están permitidos si tienen 10 años de antigüedad con la aprobación del Departamento.
- NO instale dentro de 3 pies de lo siguiente: puerta a un cuarto de baño que contenga una bañera o ducha, conductos de suministro de aire forzado, techo o ventilador de la casa entera, o otras áreas de alto flujo de aire.